

ADDRESS REPLY TO  
CHIEF OF ENGINEERS, U. S. ARMY  
WASHINGTON, D. C.

WAR DEPARTMENT  
OFFICE OF THE CHIEF OF ENGINEERS  
WASHINGTON

REFER TO FILE NO.

Room 251, Building 23  
General Electric Co.  
Schenectady, New York  
September 29, 1944

Barza Engineering Co.  
25 West Wacker Drive  
Chicago 5, Ill.

Al no. 32,000 KV. Generator  
Contract 49-013-eng-4

Gentlemen:

In inspection of the above, Hugday generator shaft  
was made here today by the following representatives:

Mr. Louis Blum, representing Government of Hugday  
Mr. Louis Blum, representing Barza Engineering Co.  
Mr. J. J. Holly, representing Int. Nat. B. & O. Co.  
Mr. J. J. Henningsen, representing Gen. Elec. Co.  
Mr. J. J. Hoff, representing Gen. Electric Co.  
Mr. J. J. Green, representing U. S. Engineers

The large roller in the lower side bearing journal  
where non-metallic inclusions were previously observed  
had been drilled, and the metal milled out between the  
drilled holes on each of the three areas.

I made a visual inspection of all three of the  
machined areas, no non-metallic inclusions could be seen,  
and only bare metal was observed.

Photographs and a print of sketch showing the  
machined areas are enclosed.

Yours very truly,

Charles E. Green

CC: Mr. J. J. Green  
Mr. J. J. Holly  
Mr. J. J. Henningsen  
Mr. J. J. Hoff

Inc. note and sketch under sep. cover

